

**Toronto Water Regulated Lead Sampling Program
Data Summary**

Testing Period	Locations	Number of Locations	Lead Result - ug/L			% of Samples ≥ 11 ug/L
			Maximum	Minumun	Average	
Round 14 * June 2014 - October 2014	Private Residential Plumbing					
	Private Residential Plumbing - (Lead ≥ 11 ug/L)					
	Non-Private Residential Plumbing					
	Distribution System **	20	0.96	<0.05	0.3	0
Round 13 * December 2013 - April 2014	Private Residential Plumbing					
	Private Residential Plumbing - (Lead ≥ 11 ug/L)					
	Non-Private Residential Plumbing					
	Distribution System **	20	1.9	0.07	0.6	0
Round 12* June 2013 - October 2013	Private Residential Plumbing					
	Private Residential Plumbing - (Lead ≥ 11 ug/L)					
	Non-Private Residential Plumbing					
	Distribution System	20	<0.5	<0.5	<0.5	0
Round 11 * December 2012 -April 2013	Private Residential Plumbing					
	Private Residential Plumbing - (Lead ≥ 11 ug/L)					
	Non-Private Residential Plumbing					
	Distribution System	20	1	<0.5	0.3	0
Round 10 * June 2012 -October 2012	Private Residential Plumbing					
	Private Residential Plumbing - (Lead ≥ 11 ug/L)					
	Non-Private Residential Plumbing					
	Distribution System	20	8	<0.5	0.9	0
Round 9 * December 2011 - April 2012	Private Residential Plumbing					
	Private Residential Plumbing - (Lead ≥ 11 ug/L)					
	Non-Private Residential Plumbing					
	Distribution System	20	2	<0.51	0.6	0
Round 8 * June 2011 - October 2011	Private Residential Plumbing					
	Private Residential Plumbing - (Lead ≥ 11 ug/L)					
	Non-Private Residential Plumbing					
	Distribution System	20	4	<0.51	1.1	0

Testing Period	Locations	Number of Locations	Lead Result - ug/L			% of Samples ≥ 11 ug/L
			Maximum	Minumun	Average	
Round 7 * December 2010 - April 2011	Private Residential Plumbing	-	-	-	-	-
	Private Residential Plumbing - (Lead ≥ 11 ug/L)	-	-	-	-	-
	Non-Private Residential Plumbing	-	-	-	-	-
	Distribution System	20	0.7	<0.51	0.1	0
Round 6 * June 2010 - October 2010	Private Residential Plumbing	-	-	-	-	-
	Private Residential Plumbing - (Lead ≥ 11 ug/L)	-	-	-	-	-
	Non-Private Residential Plumbing	-	-	-	-	-
	Distribution System	20	2	<0.51	0.5	0
Round 5 * December 2009 - April 2010	Private Residential Plumbing	-	-	-	-	-
	Private Residential Plumbing - (Lead ≥ 11 ug/L)	-	-	-	-	-
	Non-Private Residential Plumbing	-	-	-	-	-
	Distribution System	20	5	<0.51	0.7	0
Round 4 June 2009 - October 2009	Private Residential Plumbing	100	22	<0.51	6.1	18
	Private Residential Plumbing - (Lead ≥ 11 ug/L)	18	22	11	16.9	-
	Non-Private Residential Plumbing	10	15	1.0	3.3	1
	Distribution System	21	4	0	1.0	0
Round 3 December 2008 - April 2009	Private Residential Plumbing	102	38	<0.51	3.9	7
	Private Residential Plumbing - (Lead ≥ 11 ug/L)	7	38	11	16.3	-
	Non-Private Residential Plumbing	10	4	<0.51	0.7	0
	Distribution System	21	4	<0.51	0.8	0
Round 2 June 2008 - October 2008	Private Residential Plumbing	100	82	<0.51	11.9	52
	Private Residential Plumbing - (Lead ≥ 11 ug/L)	52	82	11	18.6	-
	Non-Private Residential Plumbing	10	6	<0.51	0.8	0
	Distribution System **	21	5	<0.51	0.6	0
Round 1 December 2007 - April 2008	Private Residential Plumbing	100	14	<0.51	3.8	6
	Private Residential Plumbing - (Lead ≥ 11 ug/L)	6	14	11	12.8	-
	Non-Private Residential Plumbing	10	2	<0.51	0.6	0
	Distribution System **	20	6	<0.51	0.7	0

* Relief from private and non-private residential plumbing sampling has been granted from the MOE as a Corrosion Control Plan is now being created.

** New analytical method has a lower Reporting Limit of 0.05 ug/L.

Ontario Drinking Water Quality Standard for Lead = 10 ug/L (micrograms per litre)
Results with "<" means less than the Method Detection Limit